



R.O.

RO TDS MEASUREMENT

Long Exercise Note Book

Date	Dept	ROTDs in ppm	Raw water TDS in ppm	Reverse Tank Capacity in liter	Seg
25/12/22	Dialysis	06	229	500	Normal
	Hospital	59	231	1000	Full
	Nursing	81	235	5000	Stylin
01/1/23	Dialysis	07	240	500	Full
	Hospital	80	241	1000	Full
	Nursing	78	249	5000	Stylin
8/1/23	Dialysis	08	236	500	Normal
	Hospital	65	201	1000	Full
	Nursing	67	199	5000	Stylin
15/1/23	Dialysis	07	198	500	Normal
	Hospital	67	181	1000	Full
	Nursing	65	187	5000	Stylin
22/1/23	Dialysis	08	188	500	Normal
	Hospital	68	210	1000	Full
	Nursing	70	189	5000	Stylin

Date	Dept	ROTDs in ppm	Raw water TDS in ppm	Reverse Tank Capacity in liter	Seg
31/3/22	Dialysis	07	210	500	Normal
	Hospital	70	203	1000	Full
	Nursing	76	205	5000	Stylin
5/4/22	Dialysis	06	215	500	Normal
	Hospital	78	216	1000	Full
	Nursing	77	217	5000	Stylin
12/4/22	Dialysis	05	216	500	Normal
	Hospital	59	205	1000	Full
	Nursing	55	206	5000	Stylin
18/4/22	Dialysis	06	200	500	Normal
	Hospital	61	199	1000	Full
	Nursing	60	198	5000	Stylin
25/4/22	Dialysis	07	185	500	Normal
	Hospital	63	187	1000	Full
	Nursing	62	189	5000	Stylin
30/4/22	Dialysis	06	220	500	Normal
	Hospital	65	235	1000	Full
	Nursing	67	220	5000	Stylin